

Raw Water

Sample Date / Time	Location of Sample	Parameter	Unit of Measurement	Result as NO3/l	Regulatory Limit
15/07/2024 12:00	RAW WATER	Nitrate	MG NO3/L	36.5032	50 MG NO3/L
31/07/2024 08:00	RAW WATER	Nitrate	MG NO3/L	34.997	50 MG NO3/L
20/08/2024 15:41	RAW WATER	Nitrate	MG NO3/L	34.2882	50 MG NO3/L
03/09/2024 11:12	RAW WATER	Nitrate	MG NO3/L	35.2185	50 MG NO3/L
16/09/2024 09:59	RAW WATER	Nitrate	MG NO3/L	33.0035	50 MG NO3/L
09/10/2024 08:50	RAW WATER	Nitrate	MG NO3/L	36.6804	50 MG NO3/L
16/10/2024 08:39	RAW WATER	Nitrate	MG NO3/L	35.7501	50 MG NO3/L
20/11/2024 11:13	RAW WATER	Nitrate	MG NO3/L	36.5475	50 MG NO3/L
21/11/2024 08:04	RAW WATER	Nitrate	MG NO3/L	36.9019	50 MG NO3/L
05/12/2024 07:55	RAW WATER	Nitrate	MG NO3/L	37.0791	50 MG NO3/L
27/12/2024 07:56	RAW WATER	Nitrate	MG NO3/L	36.0602	50 MG NO3/L
30/12/2024 14:48	RAW WATER	Nitrate	MG NO3/L	35.0413	50 MG NO3/L
14/01/2025 12:22	RAW WATER	Nitrate	MG NO3/L	35.883	50 MG NO3/L
23/01/2025 13:30	RAW WATER	Nitrate	MG NO3/L	38.3195	50 MG NO3/L
27/01/2025 19:05	RAW WATER	Nitrate	MG NO3/L	35.3514	50 MG NO3/L
17/02/2025 08:16	RAW WATER	Nitrate	MG NO3/L	35.2628	50 MG NO3/L
11/03/2025 08:04	RAW WATER	Nitrate	MG NO3/L	36.5475	50 MG NO3/L
17/03/2025 17:44	RAW WATER	Nitrate	MG NO3/L	36.8576	50 MG NO3/L
27/03/2025 08:16	RAW WATER	Nitrate	MG NO3/L	37.0348	50 MG NO3/L
07/04/2025 08:09	RAW WATER	Nitrate	MG NO3/L	36.1045	50 MG NO3/L
29/04/2025 08:07	RAW WATER	Nitrate	MG NO3/L	34.997	50 MG NO3/L
19/05/2025 19:05	RAW WATER	Nitrate	MG NO3/L	38.4081	50 MG NO3/L
03/06/2025 07:50	RAW WATER	Nitrate	MG NO3/L	37.1234	50 MG NO3/L
05/06/2025 10:03	RAW WATER	Nitrate	MG NO3/L	37.4778	50 MG NO3/L
16/06/2025 09:04	RAW WATER	Nitrate	MG NO3/L	37.1677	50 MG NO3/L
30/06/2025 10:42	RAW WATER	Nitrate	MG NO3/L	36.6804	50 MG NO3/L

Water Treatment Works Final Water

Sample Date / Time	Location of Sample	Parameter	Unit of Measurement	Result as NO3/L	Regulatory Limit
09/07/2024 14:03	WTW Treated Water	Nitrate	MG NO3/L	35.4843	50 MG NO3/L
10/07/2024 14:27	WTW Treated Water	Nitrate	MG NO3/L	35.6172	50 MG NO3/L
15/07/2024 11:45	WTW Treated Water	Nitrate	MG NO3/L	35.2628	50 MG NO3/L
03/08/2024 12:18	WTW Treated Water	Nitrate	MG NO3/L	33.8452	50 MG NO3/L
13/08/2024 08:22	WTW Treated Water	Nitrate	MG NO3/L	32.9592	50 MG NO3/L
03/09/2024 11:29	WTW Treated Water	Nitrate	MG NO3/L	35.0413	50 MG NO3/L
17/09/2024 09:43	WTW Treated Water	Nitrate	MG NO3/L	35.8387	50 MG NO3/L
24/09/2024 11:57	WTW Treated Water	Nitrate	MG NO3/L	35.8387	50 MG NO3/L
09/10/2024 08:28	WTW Treated Water	Nitrate	MG NO3/L	36.0602	50 MG NO3/L
24/10/2024 12:40	WTW Treated Water	Nitrate	MG NO3/L	35.2185	50 MG NO3/L
06/11/2024 08:25	WTW Treated Water	Nitrate	MG NO3/L	37.0348	50 MG NO3/L
12/11/2024 07:59	WTW Treated Water	Nitrate	MG NO3/L	36.3703	50 MG NO3/L
27/11/2024 13:45	WTW Treated Water	Nitrate	MG NO3/L	37.0791	50 MG NO3/L
05/12/2024 07:28	WTW Treated Water	Nitrate	MG NO3/L	38.2309	50 MG NO3/L
10/12/2024 07:31	WTW Treated Water	Nitrate	MG NO3/L	36.1931	50 MG NO3/L
30/12/2024 14:43	WTW Treated Water	Nitrate	MG NO3/L	33.9781	50 MG NO3/L
02/01/2025 09:58	WTW Treated Water	Nitrate	MG NO3/L	37.0348	50 MG NO3/L
09/01/2025 10:12	WTW Treated Water	Nitrate	MG NO3/L	35.8387	50 MG NO3/L
27/01/2025 18:40	WTW Treated Water	Nitrate	MG NO3/L	36.0159	50 MG NO3/L
06/02/2025 11:54	WTW Treated Water	Nitrate	MG NO3/L	38.4524	50 MG NO3/L
17/02/2025 07:58	WTW Treated Water	Nitrate	MG NO3/L	36.5475	50 MG NO3/L
01/03/2025 11:21	WTW Treated Water	Nitrate	MG NO3/L	37.0348	50 MG NO3/L
04/03/2025 13:31	WTW Treated Water	Nitrate	MG NO3/L	38.4081	50 MG NO3/L
11/03/2025 08:28	WTW Treated Water	Nitrate	MG NO3/L	36.9019	50 MG NO3/L
17/03/2025 17:32	WTW Treated Water	Nitrate	MG NO3/L	35.883	50 MG NO3/L
07/04/2025 07:50	WTW Treated Water	Nitrate	MG NO3/L	37.5221	50 MG NO3/L
07/04/2025 07:51	WTW Treated Water	Nitrate	MG NO3/L	38.098	50 MG NO3/L
23/04/2025 07:39	WTW Treated Water	Nitrate	MG NO3/L	36.9019	50 MG NO3/L
29/04/2025 07:52	WTW Treated Water	Nitrate	MG NO3/L	35.7944	50 MG NO3/L
15/05/2025 08:03	WTW Treated Water	Nitrate	MG NO3/L	38.2752	50 MG NO3/L
15/05/2025 08:04	WTW Treated Water	Nitrate	MG NO3/L	36.9462	50 MG NO3/L
03/06/2025 08:01	WTW Treated Water	Nitrate	MG NO3/L	36.4146	50 MG NO3/L
16/06/2025 09:07	WTW Treated Water	Nitrate	MG NO3/L	35.7944	50 MG NO3/L
30/06/2025 10:26	WTW Treated Water	Nitrate	MG NO3/L	36.326	50 MG NO3/L
08/07/2025 12:14	WTW Treated Water	Nitrate	MG NO3/L	34.8641	50 MG NO3/L

Water Supply Zone

Sample Date / Time	Location of Sample	Parameter	Unit of Measurement	Result as NO3/L	Regulatory Limit
16/08/2024 09:20	WSZ 024 CLIBURN	Nitrate	MG NO3/L	35.3071	50 MG NO3/L
20/11/2024 10:05	WSZ 024 CLIBURN	Nitrate	MG NO3/L	39.1169	50 MG NO3/L
08/01/2025 12:34	WSZ 024 CLIBURN	Nitrate	MG NO3/L	36.9019	50 MG NO3/L
28/01/2025 10:08	WSZ 024 CLIBURN	Nitrate	MG NO3/L	36.769	50 MG NO3/L
09/05/2025 12:17	WSZ 024 CLIBURN	Nitrate	MG NO3/L	37.5664	50 MG NO3/L